



12" #4 REBAR DOWELS AT 18" O.C.

12" #4 REBAR DOWELS AT 9" O.C.

8" #4 REBAR DOWELS 24" O.C. AT CENTER OF CROSS-SECTION OF SIDEWALK

NOTES

1. DOWELS SHALL BE INSTALLED AS SHOWN BETWEEN NEW SIDEWALK AND EXISTING CURB AND GUTTER, OR VICE VERSA.
2. DOWELS SHALL BE INSTALLED AS SHOWN AT BOTH ENDS OF NEW IMPROVEMENTS AS THEY TIE INTO EXISTING SIDEWALK, AND/OR CURB AND GUTTER. (EXCEPTION - SEE NOTE 3)
3. DOWELS SHALL NOT BE INSTALLED WHERE AN EXPANSION JOINT EXISTS, OR IS REQUIRED. EXISTING EXPANSION JOINT SHALL BE REPLACED AS REQUIRED.
4. SAWCUTS ARE TYPICALLY MADE AT EXISTING SCORE LINES.



CITY OF VALLEJO STANDARD DETAIL

STANDARD CURB, GUTTER, & SIDEWALK DOWELING DETAIL

APPROVED BY:

DIRECTOR OF PUBLIC WORKS

DRAWING NO:

3-08

SCALE:
NONE

DATE:
09/13/11