



GENERAL NOTES

1. BROOM FINISH UNLESS OTHERWISE DIRECTED.
2. TOOL SCORE LINES EVERY 4'. LONGITUDINAL SCORE LINES TO SUIT CONDITIONS OR AS DIRECTED BY ENGINEER, 16 SQ. FT. MAXIMUM.
3. USE PIGMENTED SEALING COMPOUND FOR CURING.
4. ALL #4 REBAR SHALL BE GRADE 40 OR BETTER.
5. FOR STANDARD CURB, GUTTER, AND SIDEWALK DETAILS SEE STANDARD DRAWING #3-10.
6. REBAR IS NOT REQUIRED FOR CURB WALL, UNLESS THE WALL IS SURCHARGED



CITY OF VALLEJO STANDARD DETAIL

**STANDARD
MONOLITHIC CURB WALL**

APPROVED BY:

DIRECTOR OF PUBLIC WORKS

DRAWING NO:
3-17

SCALE:
NONE

DATE:
09/13/11