



NOTES:

LONGITUDINAL SECTION

1. MAXIMUM CAPACITY = 0.15 CU. FT./SEC. AT S=1/4" PER 1' OR 2%.
2. NO PIPE JOINTS SHALL BE MADE WITHIN SIDEWALK OR CURB.
3. PVC PIPE SHALL CONFORM TO ASTM D3034 SDR35.
4. WHERE PLACING NEW CONCRETE ADJACENT TO EXISTING, DOWEL INTO EXISTING CONCRETE WITH #4 REBAR @ 2 FOOT O.C., 9 INCHES LONG WITH 3" MINIMUM EMBEDMENT. SAWCUT EXISTING CONCRETE FOR A NEAT STRAIGHT LINE FOR REMOVAL.
5. CONCRETE SHALL CONSIST OF 564 POUNDS OF PORTLAND CEMENT PER CUBIC YARD AND HAVE A MINIMUM STRENGTH OF 3000 PSI.
6. NOT FOR USE WITHIN LOW PROFILE CURB.



CITY OF VALLEJO STANDARD DETAIL

STANDARD
SIDEWALK CROSS DRAIN

APPROVED BY:

DIRECTOR OF PUBLIC WORKS

DRAWING NO:

3-19

SCALE:
NONE

DATE:
09/13/11