



NOTES:

1. SUBDRAINS MAY BE REQUIRED IN LANDSCAPED MEDIANS.
2. PORTLAND CEMENT CONCRETE SHALL CONFORM TO "MINOR CONCRETE" OF THE CALTRANS STANDARD SPECIFICATIONS EXCEPT THAT THE CEMENT CONTENT SHALL BE A MINIMUM OF 6 SACKS OF CEMENT PER CUBIC YARD OF CONCRETE.



CITY OF VALLEJO STANDARD DETAIL

**STANDARD
MEDIAN CURB**

APPROVED BY:

DIRECTOR OF PUBLIC WORKS

DRAWING NO:

3-18

SCALE:
NONE

DATE:

09/13/11